

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3230-0554:128 Page 1 of 2

CATEGORY: Leakage Dampers

LISTEE: Johnson Controls, 507 E. Michigan St., Milwaukee, WI 53202-5211*
Contact: *James D. Kinney (414) 524-4358

DESIGN: Model FS-1300 (Type TOVBE, TOVBP), SD-1300, SD-1320 (Type SOPAE, SOPAP, SOPBE, SOPBP, SPPAE, SPPAP, SPPBE, SPPBP), and SD-1330 (Type SOAAE, SOAAP, SOABE, SOABP, SPAAE, SPAAP, SPABE, SPABP) leakage rated dampers. Unit is a single and multiblade type. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:	<u>Models</u>	<u>Single Section</u>				Rating	
		<u>Width</u>	<u>Height</u>	<u>Position</u>			
		<u>Min.</u>	<u>Max.</u>	<u>Min.</u>	<u>Max.</u>		
	SD-1300	10"	48"	10"	72"	V, H	II-250
	TOVBE/TOVBP	15"	32"	8"	48"	V, H	II-250/350
		15"	32"	8"	36"		
	SOPAE/SOPAP/SPPAE/SPPAP	10"	48"	10"	76"	V, H	II-250
		10"	48"	10"	48"		
	SOPBE/SOPBP/SPPBE/SPPBP	10"	48"	12"	76"	V, H	II-350
		10"	48"	12"	48"		
	SOAAE/SOAAP/SPPAE/SPPAP	18"	48"	10"	70"	V, H	I-250
		18"	48"	10"	48"		
	SOABE/SOABP/SPABE/SPABP	18"	48"	10"	70"	V, H	I-350
		18"	48"	10"	48"		

These damper are intended for use with Models DMPR-S16024, -S16024S, -S16120, -S16120S, -S60024, -S60024S, S60120, -S60120S, D-3062, DS-3062, D-3153 or DS-3153S damper operator.

- INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
- MARKING:** Listee's name, model number, classification and UL label.
- APPROVAL:** Listed as leakage dampers for use in heating, ventilating and air conditioning systems.

*Rev. 06-10-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 10, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager